## City of Alexandria Fire Service Features for Buildings

Fire Apparatus Access Roads:	<ul> <li>150' of all portions of building</li> <li>(City code requirements)</li> <li>20' min width, 13'6"min vertical</li> <li>All weather surfaces</li> <li>Dead-end turn-a-rounds to meet Highway Standards</li> </ul>
Access to Building Openings and Roofs:	Not blocked
Premises Identification:	Address numbers (min. 4" ht.)
Key Boxes:	KNOX Box (contact Alexandria Fire Marshal)
Hazards to Fire Fighters:	Proper markings of shafts & stairways
Fire Protection Water Supplies:	Water supply test Private Service mains – 6" minimum Install to NFPA 24 Flush & Hydro Test water line (150 psi/2hrs) Hydrant locations
Fire Protection Systems:	Automatic Fire Sprinklers (were required) Install to NFPA 13 (annual test/inspections) Fire panel w/Monitoring Freeze up prevention Fire Extinguisher installation per code

AFD Fire Suppression/Detection Permit Application [Required as of 01/01/2014] (See attached form)

Hazardous materials usage & storage to meet current codes

ALL ABOVE ITEMS TO BE INSPECTED BEFORE OCCUPANCY

Detailed information on current fire codes available at Fire Department Contact Alexandria Fire Chief at 320-763-6488 or 320-808-3590





## **ALEXANDRIA FIRE DEPARTMENT**

**302 FILLMORE STREET ALEXANDRIA, MN 56308** Phone: 320-763-6489 Fax: 320-762-9723



Commercial

Industrial

Institutional

□ Multi-Family □ Public Facility

## FIRE SUPPRESSION/PROTECTION SYSTEM PERMIT APPLICATION

Date	Permit Number
Building Address	
Owner's Name	
Address	
Phone #	
Contractor's Name	
Address	
Phone #	State License #
Contractor's email	
* * * * * * * * * * * * * * * * * * *	
	System Valuation
Total Fire Suppression/Protection System Contract Amount:	
Permit Fee: \$50 Payable to	: City of Alexandria 302 Fillmore St Alexandria, MN 56308
required. This permit does not relieve the contr	I State Fire Marshal, and SFM documentation approval are ractor from compliance with appropriate Federal, State or Local on. The contractor certifies that the above information is correct.

Applicant Signature

Fire Chief Signature