## City of Alexandria Fire Service Features for Buildings

Fire Apparatus Access Roads: 150' of all portions of building

(City code requirements)
20' min width, 13'6"min vertical

All weather surfaces

Dead-end turn-a-rounds to meet Highway Standards

Access to Building Openings and Roofs: Not blocked

Premises Identification: Address numbers (min. 4" ht.)

Key Boxes: KNOX Box (contact Alexandria Fire Marshal)

Hazards to Fire Fighters: Proper markings of shafts & stairways

Fire Protection Water Supplies: Water supply test

Private Service mains - 6" minimum

Install to NFPA 24

Flush & Hydro Test water line (150 psi/2hrs)

**Hydrant locations** 

Fire Protection Systems: Automatic Fire Sprinklers (were required)

Install to NFPA 13 (annual test/inspections)

Fire panel w/Monitoring Freeze up prevention

Fire Extinguisher installation per code

AFD Fire Suppression/Detection Permit Application [Required as of 01/01/2014]

(See attached form)

Hazardous materials usage & storage to meet current codes

ALL ABOVE ITEMS TO BE INSPECTED BEFORE OCCUPANCY

Detailed information on current fire codes available at Fire Department Contact Alexandria Fire Chief at 320-763-6488 or 320-808-3590.



## **ALEXANDRIA FIRE DEPARTMENT**



302 FILLMORE STREET
ALEXANDRIA, MN 56308
-- 320-763-6489 Fax: 320-762-97

Phone: 320-763-6489 Fax: 320-762-9723

□ Industrial □ Institutional □ Public Facility □ Multi-Family



## FIRE SUPPRESSION/PROTECTION SYSTEM PERMIT APPLICATION

Date:	Permit Number:
Building Address:	
Owner's Name:	
Address:	
Phone #:	
Contractor's Name:	
Address:	_
Phone #:	
Contractor's email:	
* * * * * * * * * * * * * * * * * * *	-
	System Valuation
Total Fire Suppression/Protection S	ystem Contract Amount:
Permit Fee payable to Alexandria Fir 302 Fillmore S	re Department (\$50): St, Alexandria, MN 56308
<b>required.</b> This permit does not relieve the contra	State Fire Marshal, and SFM documentation approval are ctor from compliance with appropriate Federal, State or Local. The contractor certifies that the above information is correct.
Applicant Signature:	
Fire Chief Signature:	