

# City of Alexandria Fire Service Features for Buildings

Fire Apparatus Access Roads – 150' of all portions of building
(City code requirements)
20' min width, 13'6"min vertical
All weather surfaces
Dead-end turn-a-rounds to meet Highway Standards

Access to Building Openings and Roofs – Not blocked

Premises Identification – Address numbers (min. 4" ht.)

Key Boxes – KNOX Box (contact Alexandria Fire Marshal)

Hazards to Fire Fighters – Proper markings of shafts & stairways

Fire Protection Water Supplies – Water supply test

Private Service mains – 6" minimum

- Install to NFPA 24
- Flush & Hydro Test water line (150 psi/2hrs)
- Hydrant locations

Fire Protection Systems – Automatic Fire Sprinklers (were required)

- Install to NFPA 13 (annual test/inspections)
- Fire panel w/Monitoring
- Freeze up prevention
- Fire Extinguisher installation per code

### <u>AFD Fire Suppression/Protection Permit Application [Required as of 01/01/2014]</u> (SEE Form attached)

Hazardous materials usage & storage to meet current codes

#### ALL ABOVE ITEMS TO BE INSPECTED BEFORE OCCUPANCY

Detailed information on current fire codes available at fire department Contact Alexandria Fire Marshal at 320-763-6489 or 320-760-6466.

### **ALEXANDRIA FIRE DEPARTMENT**

302 FILLMORE STREET
ALEXANDRIA, MN 56308
Phone: 320-763-6489 Fax: 320-762-9723



□ Commercial □ Industrial □ Institutional □ Public Facility □ Multi-Family

## FIRE SUPPRESSION/PROTECTION SYSTEM PERMIT APPLICATION

Date	Permit Number
Building Address	
Owner's Name	
Address	
Contractor's Name	
	State License #
Email	
Type of Work (chec	k one): Dew Deddition Repair Delteration ion/Protection System Contract Amount:
Permit Fee: Payable to:	\$50 City of Alexandria 704 Broadway Alexandria, MN 56308
A Set of plans are re	equired.
	relieve the contractor from compliance with appropriate Federal, tions concerning this installation. The contractor certifies that the correct.
Applicant Signature	
AFD Signature	